

2018 IRC

APPROVED	
BUILDING	ERoc 9/12/22
PLANNING	
PUBLIC WORKS	
FIRE DEPT	

★ See Notes on page 3
ER

PERMIT NO: DL 2022-00065

Deck Rebuild Construction Plans

A+R deck

Address:

Lisa Kirlin
402-690-6873
770 N 10th Avenue
Blair NE 68008

Description:

Demo Existing Deck
Rebuild 14' x 12' Deck
Treated Pine Structure
Treated Pine Deck Boards
Treated Pine Railing

Structure:

6x6 Beam Posts
2x10 Beams
2x8 Joists
4x4 Rail Post
2x4 Rail Top
2x2 Rail Baluster
2x12 Stair Stringer
5/4x4 Deck Boards

Dimensions:

Depth: 12'
Width: 14'
Height: 4'

Cost:

\$14,000



Existing Deck

Nebraska Handyman - Jason Crawford - 402-719-7219 - 1500 Adams Street Blair NE 68008 - jason@nebraskahandyman.com - www.nebraskahandyman.com

APPROVAL AS A RESULT OF AN INSPECTION SHALL NOT BE CONSTRUED TO BE AN APPROVAL OF A VIOLATION OF THE PROVISIONS OF THE CODE OR OF OTHER ORDINANCES OF THIS JURISDICTION.



Nebraska Handyman - Jason Crawford - 402-719-7219 - 1500 Adams Street Blair NE 68008 - jason@nebraskahandyman.com - www.nebraskahandyman.com



Nebraska Handyman - Jason Crawford - 402-719-7219 - 1500 Adams Street Blair NE 68008 - jason@nebraskahandyman.com - www.nebraskahandyman.com



Nebraska Handyman - Jason Crawford - 402-719-7219 - 1500 Adams Street Blair NE 68008 - jason@nebraskahandyman.com - www.nebraskahandyman.com



Nebraska Handyman - Jason Crawford - 402-719-7219 - 1500 Adams Street Blair NE 68008 - jason@nebraskahandyman.com - www.nebraskahandyman.com

*All Footing must be 8" x 42" deep minimum
ERB*



Nebraska Handyman - Jason Crawford - 402-719-7219 - 1500 Adams Street Blair NE 68008 - jason@nebraskahandyman.com - www.nebraskahandyman.com